

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #5. Maintenance & Repair
Replace water-stained ceiling tiles inside classroom: #119, #123 & #128.
Clean water-stain from light fixture covers inside classrooms: #119 & #128.
Clean return line vent from dust accumulation inside classrooms: #119, #123, #128 and cafeteria (#140)
CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Inspection Conducted By: Venus Fernandez (82515)
Inspector Contact Number: Work: (305) 623-3516 ex.
Print Client Name:
Date: 4/16/2019

Inspector Signature:

Handwritten signature of the inspector.

Client Signature:

Handwritten signature of the client.